



Designation: F2249 – 18

# Standard Specification for In-Service Test Methods for Temporary Grounding Jumper Assemblies Used on De-Energized Electric Power Lines and Equipment<sup>1</sup>

This standard is issued under the fixed designation F2249; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

## 1. Scope

1.1 These specifications cover the in-service inspection and electrical testing of temporary protective grounding jumper assemblies which have been used by electrical workers in the field.

1.2 These specifications discuss methods for testing grounding jumper assemblies, which consist of the flexible cables, ferrules, clamps and connectors used in the temporary protective grounding of de-energized circuits.

1.3 Manufacturing specifications for these grounding jumper assemblies are in Specifications **F855**.

1.4 The application, care, use, and maintenance of this equipment are beyond the scope of this specification.

1.5 Units of measurement used in this specification are in the Metric system (SI) with English units given in parentheses.

1.6 The following safety hazards caveat pertains only to the test portions of this specification. *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.7 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

<sup>1</sup> This specification is under the jurisdiction of ASTM Committee **F18** on Electrical Protective Equipment for Workers and is the direct responsibility of Subcommittee **F18.45** on Mechanical Apparatus.

Current edition approved April 15, 2018. Published August 2018. Originally approved in 2003. Last previous edition approved in 2015 as F2249-03(2015). DOI: 10.1520/F2249-18.

## 2. Referenced Documents

### 2.1 *ASTM Standards*:<sup>2</sup>

**B172** Specification for Rope-Lay-Stranded Copper Conductors Having Bunch-Stranded Members, for Electrical Conductors

**B173** Specification for Rope-Lay-Stranded Copper Conductors Having Concentric-Stranded Members, for Electrical Conductors

**F855** Specifications for Temporary Protective Grounds to Be Used on De-energized Electric Power Lines and Equipment

### 2.2 *IEEE Standards*:<sup>3</sup>

**IEEE Standard 80–2013** IEEE Guide for Safety in AC Substation Grounding

**IEEE Standard 1048–2016** IEEE Guide for the Protective Grounding of Power Lines

**IEEE Standard 1246–2011** IEEE Guide for Temporary Protective Grounding Systems Used in Substations

## 3. Terminology

### 3.1 *Definitions of Terms Specific to This Standard*:

3.1.1 *grounding jumper assembly*—grounding cable with connectors and ground clamps attached, also called a *grounding jumper* or a *protective ground assembly* installed temporarily on de-energized electric power circuits for the purpose of potential equalization and to conduct a short circuit current for a specified duration (time).

<sup>2</sup> For referenced ASTM standards, visit the ASTM website, [www.astm.org](http://www.astm.org), or contact ASTM Customer Service at [service@astm.org](mailto:service@astm.org). For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

<sup>3</sup> Available from the Institute of Electrical and Electronics Engineers, Inc. (IEEE) 1828 L St., NW, Suite 1202, Washington, DC 20036–5104.

**4. Significance and Use**

4.1 Grounding jumper assemblies can be damaged by rough handling, long term usage, weathering, corrosion, or a combination thereof. This deterioration may be both physical and electrical.

4.2 The test procedures in this specification provide an objective means of determining if a grounding jumper assembly meets minimum electrical specifications. These methods permit testing of grounding jumper assemblies under controlled conditions.

4.3 Each responsible entity must determine the required safety margin for their workers during electrical fault conditions. Guidelines for use in the determination of these conditions are beyond the scope of this specification and can be found in such standards as IEEE Standard 80–2013 and IEEE Standard 1048–2016, and IEEE Standard 1246–2011.

4.4 Mechanical damage, other than broken strands, may not significantly affect the cable resistance. Close manual and visual inspection is required to detect some types of mechanical damage.

4.5 The test procedures in this specification should be performed at a time interval established by the user to ensure that defective grounding jumper assemblies are detected and removed from service in a timely manner.

4.6 Retest the grounding jumper assembly after performing any maintenance, in order to ensure its integrity.

**5. Inspection of Grounding Jumper Assemblies**

5.1 Visual inspection shall be made of all grounding jumper assemblies prior to testing.

5.1.1 If the following defects are evident, the grounding jumpers may be rejected without electrical testing:

- 5.1.1.1 Cracked or broken ferrules and clamps,
- 5.1.1.2 Exposed broken strands,
- 5.1.1.3 Cut or badly mashed or flattened cable,
- 5.1.1.4 Extensively damaged cable- covering material,
- 5.1.1.5 Swollen cable jacket or soft spots, indicating internal corrosion, and
- 5.1.1.6 Cable strands with a black deposit on them.

5.1.2 Grounding jumper assemblies which are visually defective shall be removed from service and permanently marked, tagged or destroyed (if beyond repair) to prevent re-use.


5.1.3 Before the grounding jumper assembly can be placed back in service, it must pass the inspection requirements in 5.1.1, and the electrical requirements in Section 7.

5.1.4 All physical connections should be checked for tightness with specified torque values.

**6. Cleaning and Measuring of Grounding Jumper Assembly Prior to Electrical Testing**

6.1 Identify the cable gage (AWG) and make a precise measurement of the cable length. See Fig. 1.

6.2 Thoroughly clean the jaws of the clamps with a stiff wire brush.



**FIG. 1 Resistance and Impedance of Copper Grounding Jumper Assemblies**

- Y = resistance of clamps, ferrule and portions of the cable inside the ferrule, mΩ
- L = cable length expressed in feet (ferrule to ferrule measurement to the nearest inch, not including shrouded portion of some ferrules which cover the cable insulation), and
- R = cable resistance from Table 1, mΩ/ft.

6.3 Attach the grounding jumper assembly clamps firmly to the test set.

**7. Electrical Requirements**

7.1 The user must select the test method with the desired precision and repeatability. The test instrument should be sufficiently accurate to detect at least a one foot or less change in cable length to ensure that the cable meets requirements.

7.2 Each method must take into account a precise cable resistance per foot and the length of the cable being tested.

7.3 Electrical tests relative to this standard are:

- 7.3.1 DC resistance measurements,
- 7.3.2 AC impedance measurements, and
- 7.3.3 Temperature rise measurements (supplementary method).

7.4 DC Resistance or AC Impedance Method—Equipment required includes:

- 7.4.1 A minimum 10 A dc source controllable to 5 % of output current, short circuit protected, or
- 7.4.2 A minimum 10 A ac source controllable to 5 % of output current, short circuit protected.
- 7.4.3 Measuring method for measurements of cable length calibrated in inches or centimeters.

7.5 In-Service Electrical Resistance Pass/Fail Criteria—The pass/fail criterion of a grounding jumper assembly is based on the resistance value of the assembly (cable, ferrules and clamps) which is higher than the established resistance value for new assemblies. This increase in resistance accounts for manufacturing tolerance and the expected normal deterioration of the assembly due to aging, contamination and corrosion, particularly in the contact areas of the cable ferrules and clamps. The allowable increase in resistance is such as to permit the grounding jumper assembly to perform safely during electrical faults. The grounding jumper assembly, when subjected to its rated maximum fault current and duration, must withstand the fault without its components separating, but some heat damage and discoloration is acceptable. The electrical resistance value for the pass/fail criterion is made up of two parts (Fig. 1), the cable resistance and the resistance of the

two ends containing short cable sections, ferrules and clamps. When the grounding jumper assemblies are tested with a dc source, the dc resistance of the assembly is used for the pass or fail purposes. With an ac source, the impedance of the cable and the impedance of the ends (ferrules and clamps) are used to determine if the grounding jumper fails or passes the test.

**TABLE 1 Class K Copper Cable Nominal Resistance, mΩ/ft<sup>A</sup>**

Grounding Cable Size	Resistance, mΩ/ft at 5°C (41°F)	Resistance, mΩ/ft at 20°C (68°F)	Resistance, mΩ/ft at 35°C (95°F)
#2	0.15433	0.16400	0.17367
1/0	0.09693	0.10300	0.10907
2/0	0.07773	0.08260	0.08747
4/0	0.04893	0.05200	0.05507

<sup>A</sup> 20°C Resistance values are taken from Table 2, B172–10.

**7.5.1 Cable Resistance**—Copper cables used as part of a grounding jumper assembly must be constructed in accordance with Specifications B172 or B173 as specified in Specification F855. Four cable classes are identified in Specification F855 as being acceptable cables for use in ground cable assemblies. They are Class H, Class I, Class K, and Class M. Class K cable has proven to be a very popular cable class for use in ground cable assemblies. Table 1 provides the nominal resistance values for typical sizes of Class K cables used in grounding jumper assemblies. If the user is unable to determine the specific class of cable used in a ground cable assembly, the resistance values in Table 1 are a reasonable approximation for all four cable classes. Cable resistance values for all four cable classes are located in Appendix X1 through Appendix X4.

**7.5.1.1** The cable resistance can change with ambient temperatures. A ±5.09°C (±9.16°F) change in ambient temperatures will cause a ±2 % change in the measurement of resistance values. Table 1, and Tables X1.1, X2.1, X3.1, and X4.1 give cable resistance values for a practical range of temperatures 5°C, 20°C, and 35°C (41°F, 68°F, and 95°F). Resistance values for different temperature values can be computed using Eq 1, where  $R_{20}$  is the cable resistance per foot in mΩ/ft at 20°C,  $R_{T_2}$  is the cable resistance at the desired temperature  $T_2$ , and  $T_2$  is the desired temperature in °C.

$$R_{T_2} = R_{20} * [1 + 0.00393 * (T_2 - 20)] \text{ m}\Omega/\text{ft} \quad (1)$$

**7.5.1.2** Results from the ASTM Round Robin Tests have shown that an increase in cable resistance at a given temperature due to a combination of manufacturing tolerance and aging effects should not exceed 5 %. Therefore, the maximum acceptable resistance in cables used in temporary protective grounding jumpers should be equal to or less than 1.05  $RL$ , when  $R$  = cable resistance in mΩ/ft from Table 1, and  $L$  = cable length in feet.

**7.5.2 Resistance and Impedance of Copper Grounding Jumper Assemblies**—See Table 1, X1.1, X2.1, X3.1, or X4.1.

**7.5.2.1 Maximum Resistance of the Grounding Jumper Assembly ( $R_m$ ):**

$$R_m = 1.05 RL + 2Y \text{ m}\Omega \quad (2)$$

**7.5.2.2 Maximum Impedance of the Grounding Jumper Assembly ( $Z_m$ ):**

$$Z_m = \sqrt{(1.05RL + 2Y)^2 + (XL)^2} \text{ m}\Omega \quad (3)$$

where:

$X$  = reactance of the cable in mΩ/ft.

NOTE 1—Values of  $X$  can be found in data books such as the Standard Handbook of Electrical Engineers.<sup>4</sup>

**7.5.3 Testing with a DC Source**—A dc source can be used to determine the pass/fail value for a given grounding jumper assembly. The resistance value ( $R$ ) obtained from such a measurement should be compared with the calculated limiting maximum resistance ( $R_m$ ) using Eq 2 or it can be compared to the resistance values in Tables X1.2, X2.2, X3.2, or X4.2. The calculated criterion for pass/fail is based on 2/0 cable fault tests conducted in Round Robin III (See Appendix X5). The resistance of  $Y$  in the  $R_m$  (Eq 2) has been determined by conservative analysis of the data to be 0.16 mΩ. This value is below the “fusing range” of cables that passed the fault tests. The value of  $Y = 0.16 \text{ m}\Omega$  or  $2Y = 0.32 \text{ m}\Omega$  for all cable sizes. Therefore, the pass/fail resistance value is:

$$R_m = 1.05 RL + 0.32 \text{ m}\Omega \quad (4)$$

NOTE 2—Tables X1.2, X2.2, X3.2 and X4.2 were derived from Eq 4.

**7.5.4 Testing with an AC Source**—When an ac source is used, it will determine the grounding jumper assembly impedance ( $Z$ ). This impedance is a function of the cable and the test electrode spacing. For cable spacing of 12 in. or less, the cable reactance can be very low and the impedance value can approach that of the cable resistance. The impedance ( $Z$ ) obtained from such a measurement should be compared with the calculated limiting maximum impedance ( $Z_m$ ) using Eq 3 to determine if the grounding jumper assembly has passed or failed the test. The pass/fail impedance value based on 2/0 cable fault tests is:

$$Z_m = \sqrt{(1.05 RL + 0.32)^2 + (XL)^2} \text{ m}\Omega \quad (5)$$

If multiple spacing of the cable is utilized in the test setup, the above equation becomes:

$$Z_m = \sqrt{(1.05 RL + 0.32)^2 + (X_1L_1 + X_2L_2 + \dots + X_NL_N)^2} \text{ m}\Omega \quad (6)$$

NOTE 3—AC testing measurements of grounding jumper assemblies are susceptible to errors and inconsistent results due to induction in the cable if the cable is not laid out per the test method instructions. Different instruments require different configurations (see Fig. 2).

NOTE 4—AC testing measurements of grounding jumper assemblies are susceptible to errors if metal is laid across the cable or the cable is laid across a metal object, even if the metal object is buried, such as a reinforcing bar embedded in a concrete floor.


## 8. Cleaning/Reconditioning of Grounding Jumper Assembly after Electrical Testing

**8.1** For the readings which are high, additional cleaning and tightening of the assembly may restore its electrical integrity.

**8.2** Disassemble the grounding jumper assembly and thoroughly clean the ferrule and clamp interface with isopropyl alcohol and a stiff wire brush.

**8.3** Inspect all components during the disassembly and reassembly process.

<sup>4</sup> Standard Handbook for Electrical Engineers—Thirteenth Edition by Fink & Beaty, McGraw-Hill Book Co., New York, NY.



NOTE 1—The cable configuration may have a dramatic effect on the readings. Shown above are two different methods currently in use by different manufacturers. The manufacturer of the equipment will specify the exact method to be used with their equipment.

**FIG. 2 Typical Configurations**

8.4 Reassemble the grounding jumper. All physical connections should be checked for tightness with specified torque values.

8.5 Grounding jumper assemblies that fail the electrical test after additional maintenance or repairs are performed, shall be

removed from service and permanently marked or destroyed to prevent reuse.

APPENDIXES

(Nonmandatory Information)

X1. CLASS K COPPER CABLE NOMINAL RESISTANCE VALUES

X1.1 Specification F855, Section 35.1 lists Class K cable as one of four acceptable cables for ground cable assemblies. The resistance characteristics at 20°C for typical cable sizes of Class K cable are documented in Table 2 of Specification B172. These values are repeated in Table X1.1 along with resistance values for 5°C and 35°C. These values are used in Eq 4 along with the resistance values for the cable assembly terminations to compute the total cable assembly resistance. Eq 4 was used to compute the resistance values shown in Tables X1.2 and X1.3. The resistance values in Table X1.2 are cable resistance only, no terminations. The values in Table X1.2 are intended to be added to the values in Table X1.3 to derive the

calculated resistance of the complete ground cable assembly.

X1.2 Example:

X1.2.1 Calculate the predicted resistance at 20°C for a Class K 2/0 Copper Ground Cable Assembly that is 26 ft - 4 in. long.

X1.2.2 The resistance at 20°C of the 4 in. cable section = 0.02891 mΩ.

X1.2.3 The resistance at 20°C of the 26 ft cable section = 2.57498 mΩ.

X1.2.4 The total cable assembly resistance equals 0.02891 + 2.57498 = 2.60389 mΩ.

TABLE X1.1 Class K Nominal DC Resistance (mΩ/ft)

Cable Size (AWG)	5°C (41°F)	20°C (68°F)	35°C (95°F)
#2	0.15433	0.16400	0.17367
1/0	0.09693	0.10300	0.10907
2/0	0.07773	0.08260	0.08747
4/0	0.04893	0.05200	0.05507

TABLE X1.2 R<sub>max</sub> Limits – DC Resistance (mΩ) (Cable Only)

Cable Length (in.)	#2 Cable			1/0 Cable			2/0 Cable			4/0 Cable		
	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)
1	0.01350	0.01435	0.01520	0.00848	0.00901	0.00954	0.00680	0.00723	0.00765	0.00428	0.00455	0.00482
2	0.02701	0.02870	0.03039	0.01696	0.01803	0.01909	0.01360	0.01446	0.01531	0.00856	0.00910	0.00964
3	0.04051	0.04305	0.04559	0.02544	0.02704	0.02863	0.02040	0.02168	0.02296	0.01284	0.01365	0.01446
4	0.05402	0.05740	0.06078	0.03393	0.03605	0.03817	0.02721	0.02891	0.03061	0.01713	0.01820	0.01927
5	0.06752	0.07175	0.07598	0.04241	0.04506	0.04772	0.03401	0.03614	0.03827	0.02141	0.02275	0.02409
6	0.08102	0.08610	0.09118	0.05089	0.05408	0.05726	0.04081	0.04337	0.04592	0.02569	0.02730	0.02891
7	0.09453	0.10045	0.10637	0.05937	0.06309	0.06681	0.04761	0.05059	0.05358	0.02997	0.03185	0.03373
8	0.10803	0.11480	0.12157	0.06785	0.07210	0.07635	0.05441	0.05782	0.06123	0.03425	0.03640	0.03855
9	0.12153	0.12915	0.13677	0.07633	0.08111	0.08589	0.06121	0.06505	0.06888	0.03853	0.04095	0.04337
10	0.13504	0.14350	0.15196	0.08481	0.09013	0.09544	0.06801	0.07228	0.07654	0.04281	0.04550	0.04819
11	0.14854	0.15785	0.16716	0.09330	0.09914	0.10498	0.07482	0.07950	0.08419	0.04710	0.05005	0.05300

**TABLE X1.3  $R_{max}$  Limits – DC Resistance (mΩ) (Cable + Terminations)**

Cable Length (ft)	#2 Cable			1/0 Cable			2/0 Cable			4/0 Cable		
	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)
1	0.48205	0.49220	0.50235	0.42178	0.42815	0.43452	0.40162	0.40673	0.41184	0.37138	0.37460	0.37782
2	0.64409	0.66440	0.68471	0.52355	0.53630	0.54905	0.48323	0.49346	0.50369	0.42275	0.42920	0.43565
3	0.80614	0.83660	0.86706	0.62533	0.64445	0.66357	0.56485	0.58019	0.59553	0.47413	0.48380	0.49347
4	0.96819	1.00880	1.04941	0.72711	0.75260	0.77809	0.64647	0.66692	0.68737	0.52551	0.53840	0.55129
5	1.13023	1.18100	1.23177	0.82888	0.86075	0.89262	0.72808	0.75365	0.77922	0.57688	0.59300	0.60912
6	1.29228	1.35320	1.41412	0.93066	0.96890	1.00714	0.80970	0.84038	0.87106	0.62826	0.64760	0.66694
7	1.45433	1.52540	1.59647	1.03244	1.07705	1.12166	0.89132	0.92711	0.96290	0.67964	0.70220	0.72476
8	1.61637	1.69760	1.77883	1.13421	1.18520	1.23619	0.97293	1.01384	1.05475	0.73101	0.75680	0.78259
9	1.77842	1.86980	1.96118	1.23599	1.29335	1.35071	1.05455	1.10057	1.14659	0.78239	0.81140	0.84041
10	1.94047	2.04200	2.14354	1.33777	1.40150	1.46524	1.13617	1.18730	1.23844	0.83377	0.86600	0.89824
11	2.10251	2.21420	2.32589	1.43954	1.50965	1.57976	1.21778	1.27403	1.33028	0.88514	0.92060	0.95606
12	2.26456	2.38640	2.50824	1.54132	1.61780	1.69428	1.29940	1.36076	1.42212	0.93652	0.97520	1.01388
13	2.42660	2.55860	2.69060	1.64309	1.72595	1.80881	1.38101	1.44749	1.51397	0.98789	1.02980	1.07171
14	2.58865	2.73080	2.87295	1.74487	1.83410	1.92333	1.46263	1.53422	1.60581	1.03927	1.08440	1.12953
15	2.75070	2.90300	3.05530	1.84665	1.94225	2.03785	1.54425	1.62095	1.69765	1.09065	1.13900	1.18735
16	2.91274	3.07520	3.23766	1.94842	2.05040	2.15238	1.62586	1.70768	1.78950	1.14202	1.19360	1.24518
17	3.07479	3.24740	3.42001	2.05020	2.15855	2.26690	1.70748	1.79441	1.88134	1.19340	1.24820	1.30300
18	3.23684	3.41960	3.60236	2.15198	2.26670	2.38142	1.78910	1.88114	1.97318	1.24478	1.30280	1.36082
19	3.39888	3.59180	3.78472	2.25375	2.37485	2.49595	1.87071	1.96787	2.06503	1.29615	1.35740	1.41865
20	3.56093	3.76400	3.96707	2.35553	2.48300	2.61047	1.95233	2.05460	2.15687	1.34753	1.41200	1.47647
21	3.72298	3.93620	4.14942	2.45731	2.59115	2.72499	2.03395	2.14133	2.24871	1.39891	1.46660	1.53429
22	3.88502	4.10840	4.33178	2.55908	2.69930	2.83952	2.11556	2.22806	2.34056	1.45028	1.52120	1.59212
23	4.04707	4.28060	4.51413	2.66086	2.80745	2.95404	2.19718	2.31479	2.43240	1.50166	1.57580	1.64994
24	4.20912	4.45280	4.69648	2.76264	2.91560	3.06856	2.27880	2.40152	2.52424	1.55304	1.63040	1.70776
25	4.37116	4.62500	4.87884	2.86441	3.02375	3.18309	2.36041	2.48825	2.61609	1.60441	1.68500	1.76559
26	4.53321	4.79720	5.06119	2.96619	3.13190	3.29761	2.44203	2.57498	2.70793	1.65579	1.73960	1.82341
27	4.69526	4.96940	5.24354	3.06797	3.24005	3.41213	2.52365	2.66171	2.79977	1.70717	1.79420	1.88123
28	4.85730	5.14160	5.42590	3.16974	3.34820	3.52666	2.60526	2.74844	2.89162	1.75854	1.84880	1.93906
29	5.01935	5.31380	5.60825	3.27152	3.45635	3.64118	2.68688	2.83517	2.98346	1.80992	1.90340	1.99688
30	5.18140	5.48600	5.79061	3.37330	3.56450	3.75571	2.76850	2.92190	3.07531	1.86130	1.95800	2.05471
31	5.34344	5.65820	5.97296	3.47507	3.67265	3.87023	2.85011	3.00863	3.16715	1.91267	2.01260	2.11253
32	5.50549	5.83040	6.15531	3.57685	3.78080	3.98475	2.93173	3.09536	3.25899	1.96405	2.06720	2.17035
33	5.66753	6.00260	6.33767	3.67862	3.88895	4.09928	3.01334	3.18209	3.35084	2.01542	2.12180	2.22818
34	5.82958	6.17480	6.52002	3.78040	3.99710	4.21380	3.09496	3.26882	3.44268	2.06680	2.17640	2.28600
35	5.99163	6.34700	6.70237	3.88218	4.10525	4.32832	3.17658	3.35555	3.53452	2.11818	2.23100	2.34382
36	6.15367	6.51920	6.88473	3.98395	4.21340	4.44285	3.25819	3.44228	3.62637	2.16955	2.28560	2.40165
37	6.31572	6.69140	7.06708	4.08573	4.32155	4.55737	3.33981	3.52901	3.71821	2.22093	2.34020	2.45947
38	6.47777	6.86360	7.24943	4.18751	4.42970	4.67189	3.42143	3.61574	3.81005	2.27231	2.39480	2.51729
39	6.63981	7.03580	7.43179	4.28928	4.53785	4.78642	3.50304	3.70247	3.90190	2.32368	2.44940	2.57512
40	6.80186	7.20800	7.61414	4.39106	4.64600	4.90094	3.58466	3.78920	3.99374	2.37506	2.50400	2.63294
41	6.96391	7.38020	7.79649	4.49284	4.75415	5.01546	3.66628	3.87593	4.08558	2.42644	2.55860	2.69076
42	7.12595	7.55240	7.97885	4.59461	4.86230	5.12999	3.74789	3.96266	4.17743	2.47781	2.61320	2.74859
43	7.28800	7.72460	8.16120	4.69639	4.97045	5.24451	3.82951	4.04939	4.26927	2.52919	2.66780	2.80641
44	7.45005	7.89680	8.34355	4.79817	5.07860	5.35903	3.91113	4.13612	4.36111	2.58057	2.72240	2.86423
45	7.61209	8.06900	8.52591	4.89994	5.18675	5.47356	3.99274	4.22285	4.45296	2.63194	2.77700	2.92206
46	7.77414	8.24120	8.70826	5.00172	5.29490	5.58808	4.07436	4.30958	4.54480	2.68332	2.83160	2.97988
47	7.93619	8.41340	8.89061	5.10350	5.40305	5.70260	4.15598	4.39631	4.63664	2.73470	2.88620	3.03770
48	8.09823	8.58560	9.07297	5.20527	5.51120	5.81713	4.23759	4.48304	4.72849	2.78607	2.94080	3.09553
49	8.26028	8.75780	9.25532	5.30705	5.61935	5.93165	4.31921	4.56977	4.82033	2.83745	2.99540	3.15335
50	8.42233	8.93000	9.43768	5.40883	5.72750	6.04618	4.40083	4.65650	4.91218	2.88883	3.05000	3.21118

## X2. CLASS M COPPER CABLE NOMINAL RESISTANCE VALUES

X2.1 Specification **F855**, Section 35.1 lists Class M cable as one of four acceptable cables for ground cable assemblies. The resistance characteristics at 20°C for typical cable sizes of Class M cable are documented in Table 3 of Specification **B172**. These values are repeated in **Table X2.1** along with resistance values for 5°C and 35°C. These values are used in **Eq 4** along with the resistance values for the cable assembly terminations to compute the total cable assembly resistance. **Eq 4** was used to compute the resistance values shown in **Tables X2.2 and X2.3**. The resistance values in **Table X2.2** are cable resistance only, no terminations. The values in **Table X2.2** are intended to be added to the values in **Table X2.3** to derive the

calculated resistance of the complete ground cable assembly.

### X2.2 Example:

X2.2.1 Calculate the predicted resistance at 20°C for a Class M 2/0 Copper Ground Cable Assembly that is 26 ft - 4 in. long.

X2.2.2 The resistance at 20°C of the 4 in. cable section = 0.02919 mΩ.

X2.2.3 The resistance at 20°C of the 26 ft cable section = 2.59682 mΩ.

X2.2.4 The total cable assembly resistance equals 0.02919 + 2.59682 = 2.62601 mΩ.

**TABLE X2.1 Class M Nominal DC Resistance (mΩ/ft)**

Cable Size (AWG)	5°C (41°F)	20°C (68°F)	35°C (95°F)
#2	0.15621	0.16600	0.17579
1/0	0.09787	0.10400	0.11013
2/0	0.07848	0.08340	0.08832
4/0	0.04931	0.05240	0.05549

**TABLE X2.2  $R_{max}$  Limits – DC Resistance mΩ) (Cable Only)**

Cable Length (in.)	#2 Cable			1/0 Cable			2/0 Cable			4/0 Cable		
	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)
1	0.01367	0.01453	0.01538	0.00856	0.00910	0.00964	0.00687	0.00730	0.00773	0.00431	0.00459	0.00486
2	0.02734	0.02905	0.03076	0.01713	0.01820	0.01927	0.01373	0.01460	0.01546	0.00863	0.00917	0.00971
3	0.04101	0.04358	0.04614	0.02569	0.02730	0.02891	0.02060	0.02189	0.02318	0.01294	0.01376	0.01457
4	0.05467	0.05810	0.06153	0.03425	0.03640	0.03855	0.02747	0.02919	0.03091	0.01726	0.01834	0.01942
5	0.06834	0.07263	0.07691	0.04282	0.04550	0.04818	0.03434	0.03649	0.03864	0.02157	0.02293	0.02428
6	0.08201	0.08715	0.09229	0.05138	0.05460	0.05782	0.04120	0.04379	0.04637	0.02589	0.02751	0.02913
7	0.09568	0.10168	0.10767	0.05995	0.06370	0.06745	0.04807	0.05108	0.05409	0.03020	0.03210	0.03399
8	0.10935	0.11620	0.12305	0.06851	0.07280	0.07709	0.05494	0.05838	0.06182	0.03452	0.03668	0.03884
9	0.12302	0.13073	0.13843	0.07707	0.08190	0.08673	0.06180	0.06568	0.06955	0.03883	0.04127	0.04370
10	0.13668	0.14525	0.15382	0.08564	0.09100	0.09636	0.06867	0.07298	0.07728	0.04315	0.04585	0.04855
11	0.15035	0.15978	0.16920	0.09420	0.10010	0.10600	0.07554	0.08027	0.08501	0.04746	0.05044	0.05341

**TABLE X2.3  $R_{max}$  Limits – DC Resistance (mΩ) (Cable + Terminations)**

Cable Length (ft)	#2 Cable			1/0 Cable			2/0 Cable			4/0 Cable		
	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)
1	0.48402	0.49430	0.50458	0.42276	0.42920	0.43564	0.40240	0.40757	0.41274	0.37178	0.37502	0.37826
2	0.64804	0.66860	0.68916	0.52553	0.53840	0.55127	0.48481	0.49514	0.50547	0.42355	0.43004	0.43653
3	0.81206	0.84290	0.87374	0.62829	0.64760	0.66691	0.56721	0.58271	0.59821	0.47533	0.48506	0.49479
4	0.97608	1.01720	1.05832	0.73105	0.75680	0.78255	0.64962	0.67028	0.69094	0.52710	0.54008	0.55306
5	1.14010	1.19150	1.24290	0.83382	0.86600	0.89818	0.73202	0.75785	0.78368	0.57888	0.59510	0.61132
6	1.30412	1.36580	1.42748	0.93658	0.97520	1.01382	0.81442	0.84542	0.87642	0.63065	0.65012	0.66959
7	1.46814	1.54010	1.61206	1.03934	1.08440	1.12946	0.89683	0.93299	0.96915	0.68243	0.70514	0.72785
8	1.63216	1.71440	1.79664	1.14211	1.19360	1.24509	0.97923	1.02056	1.06189	0.73420	0.76016	0.78612
9	1.79618	1.88870	1.98122	1.24487	1.30280	1.36073	1.06164	1.10813	1.15462	0.78598	0.81518	0.84438
10	1.96021	2.06300	2.16580	1.34764	1.41200	1.47637	1.14404	1.19570	1.24736	0.83776	0.87020	0.90265
11	2.12423	2.23730	2.35037	1.45040	1.52120	1.59200	1.22644	1.28327	1.34010	0.88953	0.92522	0.96091
12	2.28825	2.41160	2.53495	1.55316	1.63040	1.70764	1.30885	1.37084	1.43283	0.94131	0.98024	1.01917
13	2.45227	2.58590	2.71953	1.65593	1.73960	1.82327	1.39125	1.45841	1.52557	0.99308	1.03526	1.07744
14	2.61629	2.76020	2.90411	1.75869	1.84880	1.93891	1.47366	1.54598	1.61830	1.04486	1.09028	1.13570
15	2.78031	2.93450	3.08869	1.86145	1.95800	2.05455	1.55606	1.63355	1.71104	1.09663	1.14530	1.19397
16	2.94433	3.10880	3.27327	1.96422	2.06720	2.17018	1.63846	1.72112	1.80378	1.14841	1.20032	1.25223
17	3.10835	3.28310	3.45785	2.06698	2.17640	2.28582	1.72087	1.80869	1.89651	1.20018	1.25534	1.31050
18	3.27237	3.45740	3.64243	2.16974	2.28560	2.40146	1.80327	1.89626	1.98925	1.25196	1.31036	1.36876
19	3.43639	3.63170	3.82701	2.27251	2.39480	2.51709	1.88568	1.98383	2.08198	1.30373	1.36538	1.42703
20	3.60041	3.80600	4.01159	2.37527	2.50400	2.63273	1.96808	2.07140	2.17472	1.35551	1.42040	1.48529
21	3.76443	3.98030	4.19617	2.47803	2.61320	2.74837	2.05048	2.15897	2.26746	1.40729	1.47542	1.54355
22	3.92845	4.15460	4.38075	2.58080	2.72240	2.86400	2.13289	2.24654	2.36019	1.45960	1.53044	1.60182
23	4.09247	4.32890	4.56533	2.68356	2.83160	2.97964	2.21529	2.33411	2.45293	1.51084	1.58546	1.66008
24	4.25649	4.50320	4.74991	2.78632	2.94080	3.09528	2.29770	2.42168	2.54566	1.56261	1.64048	1.71835
25	4.42051	4.67750	4.93449	2.88909	3.05000	3.21091	2.38010	2.50925	2.63840	1.61439	1.69550	1.77661
26	4.58453	4.85180	5.11907	2.99185	3.15920	3.32655	2.46250	2.59682	2.73114	1.66616	1.75052	1.83488
27	4.74855	5.02610	5.30365	3.09461	3.26840	3.44219	2.54491	2.68439	2.82387	1.71794	1.80554	1.89314
28	4.91257	5.20040	5.48823	3.19738	3.37760	3.55782	2.62731	2.77196	2.91661	1.76971	1.86056	1.95141
29	5.07659	5.37470	5.67281	3.30014	3.48680	3.67346	2.70972	2.85953	3.00934	1.82149	1.91558	2.00967
30	5.24062	5.54900	5.85739	3.40291	3.59600	3.78910	2.79212	2.94710	3.10208	1.87327	1.97060	2.06794
31	5.40464	5.72330	6.04196	3.50567	3.70520	3.90473	2.87452	3.03467	3.19482	1.92504	2.02562	2.12620
32	5.56866	5.89760	6.22654	3.60843	3.81440	4.02037	2.95693	3.12224	3.28755	1.97682	2.08064	2.18446
33	5.73268	6.07190	6.41112	3.71120	3.92360	4.13600	3.03933	3.20981	3.38029	2.02859	2.13566	2.24273
34	5.89670	6.24620	6.59570	3.81396	4.03280	4.25164	3.12174	3.29738	3.47302	2.08037	2.19068	2.30099
35	6.06072	6.42050	6.78028	3.91672	4.14200	4.36728	3.20414	3.38495	3.56576	2.13214	2.24570	2.35926
36	6.22474	6.59480	6.96486	4.01949	4.25120	4.48291	3.28654	3.47252	3.65850	2.18392	2.30072	2.41752
37	6.38876	6.76910	7.14944	4.12225	4.36040	4.59855	3.36895	3.56009	3.75123	2.23569	2.35574	2.47579
38	6.55278	6.94340	7.33402	4.22501	4.46960	4.71419	3.45135	3.64766	3.84397	2.28747	2.41076	2.53405
39	6.71680	7.11770	7.51860	4.32778	4.57880	4.82982	3.53376	3.73523	3.93670	2.33924	2.46578	2.59232
40	6.88082	7.29200	7.70318	4.43054	4.68800	4.94546	3.61616	3.82280	4.02944	2.39102	2.52080	2.65058
41	7.04484	7.46630	7.88776	4.53330	4.79720	5.06110	3.69856	3.91037	4.12218	2.44280	2.57582	2.70884
42	7.20886	7.64060	8.07234	4.63607	4.90640	5.17673	3.78097	3.99794	4.21491	2.49457	2.63084	2.76711
43	7.37288	7.81490	8.25692	4.73883	5.01560	5.29237	3.86337	4.08551	4.30765	2.54635	2.68586	2.82537
44	7.53690	7.98920	8.44150	4.84159	5.12480	5.40801	3.94578	4.17308	4.40038	2.59812	2.74088	2.88364
45	7.70092	8.16350	8.62608	4.94436	5.23400	5.52364	4.02818	4.26065	4.49312	2.64990	2.79590	2.94190
46	7.86494	8.33780	8.81066	5.04712	5.34320	5.63928	4.11058	4.34822	4.58586	2.70167	2.85092	3.00017
47	8.02896	8.51210	8.99524	5.14988	5.45240	5.75492	4.19259	4.43579	4.67859	2.75345	2.90594	3.05843
48	8.19298	8.68640	9.17982	5.25265	5.56160	5.87055	4.27539	4.52336	4.77133	2.80522	2.96096	3.11670
49	8.35700	8.86070	9.36440	5.35541	5.67080	5.98619	4.35780	4.61093	4.86406	2.85700	3.01598	3.17496
50	8.52103	9.03500	9.54898	5.45818	5.78000	6.10183	4.44020	4.69850	4.95680	2.90878	3.07100	3.23323

### X3. CLASS H COPPER CABLE NOMINAL RESISTANCE VALUES

X3.1 Specification **F855**, Section 35.1 lists Class H cable as one of four acceptable cables for ground cable assemblies. The resistance characteristics at 20°C for typical cable sizes of Class H cable are documented in Table 3 of Specification **B173**. These values are repeated in **Table X3.1** along with resistance values for 5°C and 35°C. These values are used in **Eq 4** along with the resistance values for the cable assembly terminations to compute the total cable assembly resistance. **Eq 4** was used to compute the resistance values shown in **Tables X3.2 and X3.3**. The resistance values in **Table X3.2** are cable resistance only, no terminations. The values in **Table X3.2** are intended to be added to the values in **Table X3.3** to derive the

calculated resistance of the complete ground cable assembly.

#### X3.2 Example:

X3.2.1 Calculate the predicted resistance at 20°C for a Class H 2/0 Copper Ground Cable Assembly that is 26 ft - 4 in. long.

X3.2.2 The resistance at 20°C of the 4 in. cable section = 0.02849 mΩ.

X3.2.3 The resistance at 20°C of the 26 ft cable section = 2.54222 mΩ.

X3.2.4 The total cable assembly resistance equals 0.02849 + 2.54222 = 2.57071 mΩ.

**TABLE X3.1 Class H Nominal DC Resistance (mΩ/ft)**

Cable Size (AWG)	5°C (41°F)	20°C (68°F)	35°C (95°F)
#2	0.15339	0.16300	0.17261
1/0	0.09693	0.10300	0.10907
2/0	0.07660	0.08140	0.08620
4/0	0.04818	0.05120	0.05422

**TABLE X3.2  $R_{max}$  Limits – DC Resistance mΩ) (Cable Only)**

Cable Length (in.)	#2 Cable			1/0 Cable			2/0 Cable			4/0 Cable		
	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)
1	0.01342	0.01426	0.01510	0.00848	0.00901	0.00954	0.00670	0.00712	0.00754	0.00422	0.00448	0.00474
2	0.02684	0.02853	0.03021	0.01696	0.01803	0.01909	0.01341	0.01425	0.01509	0.00843	0.00896	0.00949
3	0.04026	0.04279	0.04531	0.02544	0.02704	0.02863	0.02011	0.02137	0.02263	0.01265	0.01344	0.01423
4	0.05369	0.05705	0.06041	0.03393	0.03605	0.03817	0.02681	0.02849	0.03017	0.01686	0.01792	0.01898
5	0.06711	0.07131	0.07552	0.04241	0.04506	0.04772	0.03351	0.03561	0.03771	0.02108	0.02240	0.02372
6	0.08053	0.08558	0.09062	0.05089	0.05408	0.05726	0.04022	0.04274	0.04526	0.02529	0.02688	0.02847
7	0.09395	0.09984	0.10572	0.05937	0.06309	0.06681	0.04692	0.04986	0.05280	0.02951	0.03136	0.03321
8	0.10737	0.11410	0.12083	0.06785	0.07210	0.07635	0.05362	0.05698	0.06034	0.03373	0.03584	0.03795
9	0.12079	0.12836	0.13593	0.07633	0.08111	0.08589	0.06032	0.06410	0.06788	0.03794	0.04032	0.04270
10	0.13422	0.14263	0.15103	0.08481	0.09013	0.09544	0.06703	0.07123	0.07543	0.04216	0.04480	0.04744
11	0.14764	0.15689	0.16614	0.09330	0.09914	0.10498	0.07373	0.07835	0.08297	0.04637	0.04928	0.05219

**TABLE X3.3  $R_{max}$  Limits – DC Resistance (mΩ) (Cable + Terminations)**

Cable Length (ft)	#2 Cable			1/0 Cable			2/0 Cable			4/0 Cable		
	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)
1	0.48106	0.49115	0.50124	0.42178	0.42815	0.43452	0.40043	0.40547	0.41051	0.37059	0.37376	0.37693
2	0.64212	0.66230	0.68248	0.52355	0.53630	0.54905	0.48086	0.49094	0.50102	0.42118	0.42752	0.43386
3	0.80318	0.83345	0.86372	0.62533	0.64445	0.66357	0.56129	0.57641	0.59153	0.47177	0.48128	0.49079
4	0.96424	1.00460	1.04496	0.72711	0.75260	0.77809	0.64172	0.66188	0.68204	0.52236	0.53504	0.54772
5	1.12530	1.17575	1.22620	0.82888	0.86075	0.89262	0.72215	0.74735	0.77255	0.57295	0.58880	0.60466
6	1.28636	1.34690	1.40744	0.93066	0.96890	1.00714	0.80258	0.83282	0.86306	0.62353	0.64256	0.66159
7	1.44742	1.51805	1.58868	1.03244	1.07705	1.12166	0.88301	0.91829	0.95357	0.67412	0.69632	0.71852
8	1.60848	1.68920	1.76992	1.13421	1.18520	1.23619	0.96344	1.00376	1.04408	0.72471	0.75008	0.77545
9	1.76954	1.86035	1.95116	1.23599	1.29335	1.35071	1.04387	1.08923	1.13459	0.77530	0.80384	0.83238
10	1.93060	2.03150	2.13241	1.33777	1.40150	1.46524	1.12430	1.17470	1.22510	0.82589	0.85760	0.88931
11	2.09165	2.20265	2.31365	1.43954	1.50965	1.57976	1.20473	1.26017	1.31561	0.87648	0.91136	0.94624
12	2.25271	2.37380	2.49489	1.54132	1.61780	1.69428	1.28516	1.34564	1.40612	0.92707	0.96512	1.00317
13	2.41377	2.54495	2.67613	1.64309	1.72595	1.80881	1.36559	1.43111	1.49663	0.97766	1.01888	1.06010
14	2.57483	2.71610	2.85737	1.74487	1.83410	1.92333	1.44602	1.51658	1.58714	1.02825	1.07264	1.11703
15	2.73589	2.88725	3.03861	1.84665	1.94225	2.03785	1.52645	1.60205	1.67765	1.07884	1.12640	1.17397
16	2.89695	3.05840	3.21985	1.94842	2.05040	2.15238	1.60688	1.68752	1.76816	1.12942	1.18016	1.23090
17	3.05801	3.22955	3.40109	2.05020	2.15855	2.26690	1.68731	1.77299	1.85867	1.18001	1.23392	1.28783
18	3.21907	3.40070	3.58233	2.15198	2.26670	2.38142	1.76774	1.85846	1.94918	1.23060	1.28768	1.34476
19	3.38013	3.57185	3.76357	2.25375	2.37485	2.49595	1.84817	1.94393	2.03969	1.28119	1.34144	1.40169
20	3.54119	3.74300	3.94481	2.35553	2.48300	2.61047	1.92860	2.02940	2.13020	1.33178	1.39520	1.45862
21	3.70225	3.91415	4.12605	2.45731	2.59115	2.72499	2.00903	2.11487	2.22071	1.38237	1.44896	1.51555
22	3.86331	4.08530	4.30729	2.55908	2.69930	2.83952	2.08946	2.20034	2.31122	1.43296	1.50272	1.57248
23	4.02437	4.25645	4.48853	2.66086	2.80745	2.95404	2.16989	2.28581	2.40173	1.48355	1.55648	1.62941
24	4.18543	4.42760	4.66977	2.76264	2.91560	3.06856	2.25032	2.37128	2.49224	1.53414	1.61024	1.68634
25	4.34649	4.59875	4.85101	2.86441	3.02375	3.18309	2.33075	2.45675	2.58275	1.58473	1.66400	1.74328
26	4.50755	4.76990	5.03225	2.96619	3.13190	3.29761	2.41118	2.54222	2.67326	1.63531	1.71776	1.80021
27	4.66861	4.94105	5.21349	3.06797	3.24005	3.41213	2.49161	2.62769	2.76377	1.68590	1.77152	1.85714
28	4.82967	5.11220	5.39473	3.16974	3.34820	3.52666	2.57204	2.71316	2.85428	1.73649	1.82528	1.91407
29	4.99073	5.28335	5.57597	3.27152	3.45635	3.64118	2.65247	2.79863	2.94479	1.78708	1.87904	1.97100
30	5.15179	5.45450	5.75722	3.37330	3.56450	3.75571	2.73290	2.88410	3.03530	1.83767	1.93280	2.02793
31	5.31284	5.62565	5.93846	3.47507	3.67265	3.87023	2.81333	2.96957	3.12581	1.88826	1.98566	2.08486
32	5.47390	5.79680	6.11970	3.57685	3.78080	3.98475	2.89376	3.05504	3.21632	1.93885	2.04032	2.14179
33	5.63496	5.96795	6.30094	3.67862	3.88895	4.09928	2.97419	3.14051	3.30683	1.98944	2.09408	2.19872
34	5.79602	6.13910	6.48218	3.78040	3.99710	4.21380	3.05462	3.22598	3.39734	2.04003	2.14784	2.25565
35	5.95708	6.31025	6.66342	3.88218	4.10525	4.32832	3.13505	3.31145	3.48785	2.09062	2.20160	2.31259
36	6.11814	6.48140	6.84466	3.98395	4.21340	4.44285	3.21548	3.39692	3.57836	2.14120	2.25536	2.36952
37	6.27920	6.65255	7.02590	4.08573	4.32155	4.55737	3.29591	3.48239	3.66887	2.19179	2.30912	2.42645
38	6.44026	6.82370	7.20714	4.18751	4.42970	4.67189	3.37634	3.56786	3.75938	2.24238	2.36288	2.48338
39	6.60132	6.99485	7.38838	4.28928	4.53785	4.78642	3.45677	3.65333	3.84989	2.29297	2.41664	2.54031
40	6.76238	7.16600	7.56962	4.39106	4.64600	4.90094	3.53720	3.73880	3.94040	2.34356	2.47040	2.59724
41	6.92344	7.33715	7.75086	4.49284	4.75415	5.01546	3.61763	3.82427	4.03091	2.39415	2.52416	2.65417
42	7.08450	7.50830	7.93210	4.59461	4.86230	5.12999	3.69806	3.90974	4.12142	2.44474	2.57792	2.71110
43	7.24556	7.67945	8.11334	4.69639	4.97045	5.24451	3.77849	3.99521	4.21193	2.49533	2.63168	2.76803
44	7.40662	7.85060	8.29458	4.79817	5.07860	5.35903	3.85892	4.08068	4.30244	2.54592	2.68544	2.82496
45	7.56768	8.02175	8.47582	4.89994	5.18675	5.47356	3.93935	4.16615	4.39295	2.59651	2.73920	2.88190
46	7.72874	8.19290	8.65706	5.00172	5.29490	5.58808	4.01978	4.25162	4.48346	2.64709	2.79296	2.93883
47	7.88980	8.36405	8.83830	5.10350	5.40305	5.70260	4.10021	4.33709	4.57397	2.69768	2.84672	2.99576
48	8.05086	8.53520	9.01954	5.20527	5.51120	5.81713	4.18064	4.42256	4.66448	2.74827	2.90048	3.05269
49	8.21192	8.70635	9.20078	5.30705	5.61935	5.93165	4.26107	4.50803	4.75499	2.79886	2.95424	3.10962
50	8.37298	8.87750	9.38203	5.40883	5.72750	6.04618	4.34150	4.59350	4.84550	2.84945	3.00800	3.16655

#### X4. CLASS I COPPER CABLE NOMINAL RESISTANCE VALUES

X4.1 Specification **F855**, Section 35.1 lists Class I cable as one of four acceptable cables for ground cable assemblies. The resistance characteristics at 20°C for typical cable sizes of Class I cable are documented in Table 1 of Specification **B172**. These values are repeated in **Table X4.1** along with resistance values for 5°C and 35°C. These values are used in **Eq 4** along with the resistance values for the cable assembly terminations to compute the total cable assembly resistance. **Eq 4** was used to compute the resistance values shown in **Tables X4.2 and X4.3**. The resistance values in **Table X4.2** are cable resistance only, no terminations. The values in **Table X4.2** are intended to be added to the values in **Table X4.3** to derive the calculated

resistance of the complete ground cable assembly.

##### X4.2 Example:

X4.2.1 Calculate the predicted resistance at 20°C for a Class I 2/0 Copper Ground Cable Assembly that is 26 ft - 4 in. long.

X4.2.2 The resistance at 20°C of the 4 in. cable section = 0.02863 mΩ.

X4.2.3 The resistance at 20°C of the 26 ft cable section = 2.55314 mΩ.

X4.2.4 The total cable assembly resistance equals 0.02863 + 2.55314 = 2.58177 mΩ.

**TABLE X4.1 Class I Nominal DC Resistance (mΩ/ft)**

Cable Size (AWG)	5°C (41°F)	20°C (68°F)	35°C (95°F)
#2	0.15339	0.16300	0.17261
1/0	0.09693	0.10300	0.10907
2/0	0.07698	0.08180	0.08662
4/0	0.04846	0.05150	0.05454

**TABLE X4.2  $R_{max}$  Limits—DC Resistance (mΩ) (Cable Only)**

Cable Length (in.)	#2 Cable			1/0 Cable			2/0 Cable			4/0 Cable		
	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)
1	0.01342	0.01426	0.01510	0.00848	0.00901	0.00954	0.00674	0.00716	0.00758	0.00424	0.00451	0.00477
2	0.02684	0.02853	0.03021	0.01696	0.01803	0.01909	0.01347	0.01432	0.01516	0.00848	0.00901	0.00954
3	0.04026	0.04279	0.04531	0.02544	0.02704	0.02863	0.02021	0.02147	0.02274	0.01272	0.01352	0.01432
4	0.05369	0.05705	0.06041	0.03393	0.03605	0.03817	0.02694	0.02863	0.03032	0.01696	0.01803	0.01909
5	0.06711	0.07131	0.07552	0.04241	0.04506	0.04772	0.03368	0.03579	0.03790	0.02120	0.02253	0.02386
6	0.08053	0.08558	0.09062	0.05089	0.05408	0.05726	0.04041	0.04295	0.04548	0.02544	0.02704	0.02863
7	0.09395	0.09984	0.10572	0.05937	0.06309	0.06681	0.04715	0.05010	0.05305	0.02968	0.03154	0.03341
8	0.10737	0.11410	0.12083	0.06785	0.07210	0.07635	0.05389	0.05726	0.06063	0.03392	0.03605	0.03818
9	0.12079	0.12836	0.13593	0.07633	0.08111	0.08589	0.06062	0.06442	0.06821	0.03816	0.04056	0.04295
10	0.13422	0.14263	0.15103	0.08481	0.09013	0.09544	0.06736	0.07158	0.07579	0.04240	0.04506	0.04772
11	0.14764	0.15689	0.16614	0.09330	0.09914	0.10498	0.07409	0.07873	0.08337	0.04664	0.04957	0.05249

TABLE X4.3  $R_{max}$  Limits—DC Resistance (mΩ) (Cable + Terminations)

Cable Length (ft)	#2 Cable			1/0 Cable			2/0 Cable			4/0 Cable		
	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)	5°C (41°F)	20°C (68°F)	35°C (95°F)
1	0.48106	0.49115	0.50124	0.42178	0.42815	0.43452	0.40083	0.40589	0.41095	0.37088	0.37408	0.37727
2	0.64212	0.66230	0.68248	0.52355	0.53630	0.54905	0.48166	0.49178	0.50190	0.42177	0.42815	0.43453
3	0.80318	0.83345	0.86372	0.62533	0.64445	0.66357	0.56249	0.57767	0.59285	0.47265	0.48223	0.49180
4	0.96424	1.00460	1.04496	0.72711	0.75260	0.77809	0.64332	0.66356	0.68380	0.52353	0.53630	0.54907
5	1.12530	1.17575	1.22620	0.82888	0.86075	0.89262	0.72415	0.74945	0.77476	0.57442	0.59038	0.60634
6	1.28636	1.34690	1.40744	0.93066	0.96890	1.00714	0.80497	0.83534	0.86571	0.62530	0.64445	0.66360
7	1.44742	1.51805	1.58868	1.03244	1.07705	1.12166	0.88580	0.92123	0.95666	0.67618	0.69853	0.72087
8	1.60848	1.68920	1.76992	1.13421	1.18520	1.23619	0.96663	1.00712	1.04761	0.72706	0.75260	0.77814
9	1.76954	1.86035	1.95116	1.23599	1.29335	1.35071	1.04746	1.09301	1.13856	0.77795	0.80668	0.83540
10	1.93060	2.03150	2.13241	1.33777	1.40150	1.46524	1.12829	1.17890	1.22951	0.82883	0.86075	0.89267
11	2.09165	2.20265	2.31365	1.43954	1.50965	1.57976	1.20912	1.26479	1.32046	0.87971	0.91483	0.94994
12	2.25271	2.37380	2.49489	1.54132	1.61780	1.69428	1.28995	1.35068	1.41141	0.93060	0.96890	1.00720
13	2.41377	2.54495	2.67613	1.64309	1.72595	1.80881	1.37078	1.43657	1.50236	0.98148	1.02298	1.06447
14	2.57483	2.71610	2.85737	1.74487	1.83410	1.92333	1.45161	1.52246	1.59331	1.03236	1.07705	1.12174
15	2.73589	2.88725	3.03861	1.84665	1.94225	2.03785	1.53244	1.60835	1.68427	1.08325	1.13113	1.17901
16	2.89695	3.05840	3.21985	1.94842	2.05040	2.15238	1.61326	1.69424	1.77522	1.13413	1.18520	1.23627
17	3.05801	3.22955	3.40109	2.05020	2.15855	2.26690	1.69409	1.78013	1.86617	1.18501	1.23928	1.29354
18	3.21907	3.40070	3.58233	2.15198	2.26670	2.38142	1.77492	1.86602	1.95712	1.23589	1.29335	1.35081
19	3.38013	3.57185	3.76357	2.25375	2.37485	2.49595	1.85575	1.95191	2.04807	1.28678	1.34743	1.40807
20	3.54119	3.74300	3.94481	2.35553	2.48300	2.61047	1.93658	2.03780	2.13902	1.33766	1.40150	1.46534
21	3.70225	3.91415	4.12605	2.45731	2.59115	2.72499	2.01741	2.12369	2.22997	1.38854	1.45558	1.52261
22	3.86331	4.08530	4.30729	2.55908	2.69930	2.83952	2.09824	2.20958	2.32092	1.43943	1.50965	1.57987
23	4.02437	4.25645	4.48853	2.66086	2.80745	2.95404	2.17907	2.29547	2.41187	1.49031	1.56373	1.63714
24	4.18543	4.42760	4.66977	2.76264	2.91560	3.06856	2.25990	2.38136	2.50282	1.54119	1.61780	1.69441
25	4.34649	4.59875	4.85101	2.86441	3.02375	3.18309	2.34073	2.46725	2.59378	1.59208	1.67188	1.75168
26	4.50755	4.76990	5.03225	2.96619	3.13190	3.29761	2.42155	2.55314	2.68473	1.64296	1.72595	1.80894
27	4.66861	4.94105	5.21349	3.06797	3.24005	3.41213	2.50238	2.63903	2.77568	1.69384	1.78003	1.86621
28	4.82967	5.11220	5.39473	3.16974	3.34820	3.52666	2.58321	2.72492	2.86663	1.74472	1.83410	1.92348
29	4.99073	5.28335	5.57597	3.27152	3.45635	3.64118	2.66404	2.81081	2.95758	1.79561	1.88818	1.98074
30	5.15179	5.45450	5.75722	3.37330	3.56450	3.75571	2.74487	2.89670	3.04853	1.84649	1.94225	2.03801
31	5.31284	5.62565	5.93846	3.47507	3.67265	3.87023	2.82570	2.98259	3.13948	1.89737	1.99633	2.09528
32	5.47390	5.79680	6.11970	3.57685	3.78080	3.98475	2.90653	3.06848	3.23043	1.94826	2.05040	2.15254
33	5.63496	5.96795	6.30094	3.67862	3.88895	4.09928	2.98736	3.15437	3.32138	1.99914	2.10448	2.20981
34	5.79602	6.13910	6.48218	3.78040	3.99710	4.21380	3.06819	3.24026	3.41233	2.05002	2.15855	2.26708
35	5.95708	6.31025	6.66342	3.88218	4.10525	4.32832	3.14902	3.32615	3.50329	2.10091	2.21263	2.32435
36	6.11814	6.48140	6.84466	3.98395	4.21340	4.44285	3.22984	3.41204	3.59424	2.15179	2.26670	2.38161
37	6.27920	6.65255	7.02590	4.08573	4.32155	4.55737	3.31067	3.49793	3.68519	2.20267	2.32078	2.43888
38	6.44026	6.82370	7.20714	4.18751	4.42970	4.67189	3.39150	3.58382	3.77614	2.25355	2.37485	2.49615
39	6.60132	6.99485	7.38838	4.28928	4.53785	4.78642	3.47233	3.66971	3.86709	2.30444	2.42893	2.55341
40	6.76238	7.16600	7.56962	4.39106	4.64600	4.90094	3.55316	3.75560	3.95804	2.35532	2.48300	2.61068
41	6.92344	7.33715	7.75086	4.49284	4.75415	5.01546	3.63399	3.84149	4.04899	2.40620	2.53708	2.66795
42	7.08450	7.50830	7.93210	4.59461	4.86230	5.12999	3.71482	3.92738	4.13994	2.45709	2.59115	2.72521
43	7.24556	7.67945	8.11334	4.69639	4.97045	5.24451	3.79565	4.01327	4.23089	2.50797	2.64523	2.78248
44	7.40662	7.85060	8.29458	4.79817	5.07860	5.35903	3.87648	4.09916	4.32184	2.55885	2.69930	2.83975
45	7.56768	8.02175	8.47582	4.89994	5.18675	5.47356	3.95731	4.18505	4.41280	2.60974	2.75338	2.89702
46	7.72874	8.19290	8.65706	5.00172	5.29490	5.58808	4.03813	4.27094	4.50375	2.66062	2.80745	2.95428
47	7.88980	8.36405	8.83830	5.10350	5.40305	5.70260	4.11896	4.35683	4.59470	2.71150	2.86153	3.01155
48	8.05086	8.53520	9.01954	5.20527	5.51120	5.81713	4.19979	4.44272	4.68565	2.76238	2.91560	3.06882
49	8.21192	8.70635	9.20078	5.30705	5.61935	5.93165	4.28062	4.52861	4.77660	2.81327	2.96968	3.12608
50	8.37298	8.87750	9.38203	5.40883	5.72750	6.04618	4.36145	4.61450	4.86755	2.86415	3.02375	3.18335

X5. DATA ANALYSIS OF ASTM—BPA GROUNDING JUMPER ASSEMBLY TESTS

X5.1 This data was used in the development of this specification and is included for informational purposes only. This data will not be included in future revisions of this specification.





FIG. X5.1 Resistance Areas

**TABLE X5.1 2/0 Copper Cables that Passed the High Current Fault Tests**

Total Length: A, C, B			
Length, ft	Calculated mΩ	Actual mΩ Reading	Percent Difference
15	1.2	1.24	3.4
18.5	1.48	1.52	2.7
20	1.6	1.64	2.6
30	2.4	2.5	4.2
35	2.8	2.9	3.6
35	2.8	3.11	11.1
40	3.2	3.31	3.4
40	3.2	3.29	2.8
Middle Section: C			
Length-2, ft	Calculated mΩ	Actual mΩ Reading	Percent Difference
13	1.04	1.09	4.5
16.5	1.32	1.31	-0.4
18	1.44	1.48	2.6
28	2.24	2.31	3.1
33	2.64	2.73	3.4
33	2.64	2.79	5.7
38	3.04	3.14	3.3
38	3.04	3.11	2.3

Ends: A and B




- (a) Total Range: 0.08 to 0.183
- (b) Passing Range: 0.08 to 0.183
- Avg = 0.094 mΩ
- Ontario Hydro = 0.160

**TABLE X5.2 2/0 Copper Grounding Jumper Assemblies that Passed the High Current Fault Tests with Some Fusing**

Total Length: A, C, B			
Length, ft	Calculated mΩ	Actual mΩ Reading	Percent Difference
6	0.48	2.04	325
8	0.64	0.94	47
10	0.8	0.83	3.3
10	0.8	0.83	3.8
10	0.8	0.83	4.3
10	0.8	0.83	4.4
10	0.8	0.83	4.3
12	0.96	2.04	112.5
15	1.2	1.23	2.3
30	2.4	2.5	4.2
35	2.8	8.35	198
Middle Section: C			
Length-2, ft	Calculated mΩ	Actual mΩ Reading	Percent Difference
4	0.32	0.42	31.3
6	0.48	0.486	1.3
8	0.64	0.645	0.8
8	0.64	0.646	0.9
8	0.64	0.657	1.9
8	0.64	0.647	1.1
8	0.64	0.652	1.9
10	0.8	0.837	4.6
13	1.04	1.084	4.2
28	2.24	2.31	3.1
33	2.64	7.53	185.2

Ends: A and B



- (a) Total Range: 0.07 to 1.486
- (b) Fusing Range: 0.353 to 1.486
- The high end number (1.486) could be in the fusing-failure range, so new fusing range is 0.353 to 0.77
- Avg = 0.56 mΩ (0.407 mΩ for Ontario Hydro)


**TABLE X5.3 2/0 Copper Grounding Jumper Assemblies that Failed the High Current Fault Tests**

Total Length: A, C, B			
Length, ft	Calculated mΩ	Actual mΩ Reading	Percent Difference
6	0.48	1.72	258
6	0.48	3.04	533
7	0.56	1.47	162
8	0.64	1.26	97
10	0.8	3.55	344
10	0.8	1.17	46
13	1.04	7.92	662
19	1.52	1.59	4.3
19	1.52	2.2	45
35	2.8	8.35	198

Middle Section: C			
Length-2, ft	Calculated mΩ	Actual mΩ Reading	Percent Difference
4	0.32	0.390	21.9
4	0.32	0.391	22.2
5	0.4	1.198	199
6	0.48	0.598	24.6
8	0.64	0.69	7.8
8	0.64	0.754	17.8
11	0.88	0.965	9.7
17	1.36	1.234	-9.3
17	1.36	1.663	22.3
33	2.64	7.53	185

Ends: A and B



(a) Total Range: 0.14 to 3.19  
 (b) Failure Range of the Test Samples: 1.153 to 3.19  
 Avg = 2.25 mΩ

**X6. TEMPERATURE DIFFERENTIAL TEST METHOD FOR IN SERVICE TESTING OF COPPER GROUNDING JUMPER ASSEMBLIES**

**X6.1 Temperature Differential Measurements**

X6.1.1 All precautions and inspections required in the dc and ac test method shall be adhered to. This test method can be used as a supplement to the test methods outlined in Section 7 of this specification.

**X6.2 Temperature Differential Method**

X6.2.1 Equipment requirements include:

X6.2.1.1 AC High Current Source, 200 amps minimum and controllable to 5 % of the output current, short circuit protected. The current source should have a continuous duty cycle rating of the current values needed to apply the continuous

rating A RMS 60 Hz per Specifications F855 Table 2, Protective Ground Cable Ferrule, and Assembly Ratings.

X6.2.1.2 Digital Multimeter, optional—Used to screen grounding jumper assembly for full 3 min test interval; commonly available with a minimum 3½ or 4½ digit meter.

X6.2.1.3 Measuring Tape, optional—Used if voltage screening method is utilized; for measurements of cable length to the nearest inch or centimeter.

X6.2.1.4 Non-contact Thermometer, infrared with digital readout (laser sighting recommended—observe normal eye protection requirements when handling lasers). Check specific manufacturer’s instruction book for emissivity setting for test

area background. **Warning**—Background temperature can influence the temperature readings.

X6.2.1.5 *Adequate Hand Protection*, defective cables may develop hot spots during testing.

### X6.3 Test Set-up

X6.3.1 Test should be performed indoors if possible or out of direct sunlight.

X6.3.2 For best accuracy, grounding jumper assembly temperature should be allowed to reach equilibrium with the test environment. (This is essential for large mass connectors and dead front grounding assemblies.)

X6.3.3 To minimize the impedance effect of AC testing, it is recommended that the grounding jumper assembly under test be laid out in a tight parallel configuration.

### X6.4 Test Procedure

X6.4.1 Connect the grounding jumper assembly to the high current source. Torque the clamps to the manufacturers' specifications (typically 25 ft/lb).

X6.4.2 Apply the rated current, per Specifications **F855** Table 5, for 3 min (see **Note X6.3**). Immediately after the 3 min, reduce the current to zero and turn off the current source. Scan the entire ground assembly, including the cable, with the infrared thermometer held 12 in. from the ground assembly. (In the case of deadfront underground assemblies, the elbow

should be removed from the feedthru and the temperature of both the elbow and feedthru bushing's current path measured.)

X6.4.3 The pass/fail criteria of a ground jumper assembly is based on the temperature variance (differential) of any components of the ground jumper assembly after the 3 min test. All components should read within 15°F (or 8.3°C) of each other. Large-mass ground components will have less temperature variance and acceptance values should be based on user experience. Small-mass grounding clamps composed of bronze (ball and socket style) will have a higher temperature variance and acceptance values should be based on user experience.

X6.4.4 Should any part of the grounding jumper assembly exceed the temperature of another part of the assembly by 15°F or more, it shall be disassembled, inspected, repaired and reassembled. The repaired assembly shall be retested.

**NOTE X6.1**—AC testing measurements of grounding jumper assembly are susceptible to errors and inconsistent results due to induction if the cable is not properly laid out.

**NOTE X6.2**—AC testing measurements of grounding jumper assembly are susceptible to errors if metal is laid across the cable or the cable is laid across a metal object, even if the metal object is buried, such as reinforcing bar embedded in a concrete floor.

**NOTE X6.3**—If the voltage drop measured across the grounding jumper assembly exceeds the allowable in the AC Test Tables, the test need not run the full three minutes. The location(s) of the high resistance can be quickly determined by scanning the grounding jumper assembly with the infrared thermometer, halting the test and repairing the grounding assembly.

*ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.*

*This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.*

*This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; http://www.copyright.com/*